



---

Royalite Manufacturing Inc.  
[www.royalite-mfg.com](http://www.royalite-mfg.com)

1055 Terminal Way, San Carlos, Ca. 94070  
(650) 637-1440, Fax (650) 673-9770

---

***Subject: Code Compliance Evaluation  
Royalite Residential Series Acrylic Dome and Single-lite Glass Skylights***

---

**The Royalite Residential Series Acrylic Dome and Single-lite Glass Skylights meet the Structural loading requirements of the 2010 California Building Code (CBC) and the 2009 International Building Code.**

I have investigated the status of the Royalite Residential Series Skylights with respect to testing performed for ICBO report ER-5377 compared with the requirements of American Architectural Manufacturer's Association specification (AAMA/WDMA/CSA 101/I.S.2/A440-05) which is cited in the 2010 CBC.

The specific requirements for materials, installation and allowable loads called for are acceptable under the current codes. The Royalite products meet or exceed the AAMA/WDMA/CSA 101/I.S.2/A440 design requirements for positive and negative design pressure. The fixed units exceed the requirements of Performance Class HC and the operable units exceed the requirements of Performance Class R.

Michael "Tony" Regan  
Structural Engineer  
10580 N. McCarran Blvd. #115-181  
Reno, NV. 89503



JUN 14 2011